

Energy Efficiency Assessments to Industrial Plants in Florida

Dr. C. Cardenas-Lailhacar

*Dept. of Mechanical and Aerospace Engineering
University of Florida*



10th Annual Market Transformation Conference
September 13-15, 2022
Hilton West Palm Beach, West Palm Beach, FL



Mapping The Energy Landscape Of Water And Wastewater Treatment Plants In The State Of Florida

Florida Department of Agricultural and Consumer Services Office of Energy

Acknowledgements

Dr. S.A. Sherif

*Professor and Director UF Industrial Assessment Center (UF-IAC)
Department of Mechanical and Aerospace Engineering
Herbert Wertheim College of Engineering, University of Florida*

The UF-IAC Students



Greetings



GATOR
Engineering



UNIVERSITY OF
FLORIDA


Outline

- Industrial Energy Audits
- Baseline and Metrics
- Energy Savings Opportunities
- The Implementation Rates and The Gaps
- The Wastewater Treatment Plants Case
- Emerging Energy Efficiency Technologies and ESCOs
- Conclusions



Industrial Assessment Centers 2022-2026

[HTTPS://IAC.UNIVERSITY](https://iac.university)




- IAC program was established in 1976 as the Energy Analysis and Diagnostic Center (EADC)
- In the 2021-2026 funding cycle, there are 31 Industrial Assessment Centers (IACs) in the US
- The UF-IAC was established in 1991 and has been in existence ever since
- The UF-IAC performs free energy assessments to midsize manufacturing facilities in Florida
- Scope of work involves energy efficiency, productivity enhancement, and waste management.

Industrial Energy Audit

IDEAS

COMPETITIVENESS & INNOVATION



ENERGY AUDITS = EMS

E Policy = Objectives

- Incentives
- Training
- Energy Eff Team
- Energy Targets
- Social Commitmen

Energy Policy

Energy
Targets

Energy Team

Training

M & V

M & V:

- Metrics
- Energy Use
- GHG Emmisions
- Carbon Credits
- Economic Variables
- Regulations
- Effects in the Market

Implementation:

- Conservation
- E. Eff. Oportunities
- SGE & ERNC
- Self-Generation

Implementation

Energy Audit:

- Audit
- Benchmarking
- Energy Bills
- NCRE
- Sustainability
- Baseline & Metrics
- Energy Balance

Energy
Audit

Energy Efficiency Benefits

INCREASES COMPETITIVENESS

INCREASES PRODUCTIVITY

REDUCES WASTE

IMPROVES ENVIRONMENTAL PERFORMANCE

LOW PRODUCTION COSTS

ENERGY EFFICIENCY

Why Not Implementing EE in Industry

- Low ROI
- Initial Cost too High
- Flow of \$ Doesn't Allow it
- High Operational Costs
- Impractical
- Processes/Equipment Changes
- Plant has Changed
- Personnel Changes
- Production Plan Changes
- Unknown
- Burocratic Restrictions
- Lack of Staff for Analysis and/or Implementation
- Not Worth it
- In disagreement
- Risk or Inconvenience for personnel
- Sospicious of Risk/Problem with Equipment or Producto
- Discarded, Imp. Failed
- Other



Bottom Line: Move Industry

FROM

“Motivated Confussion”

- Recognices the value of EE but ...
- Confussion on HOW to Proceed, and
- The Problem is TOO big and therefore:
- Results: Little or NO Action

TO

“Informed Actions”


- Apply Methods and Tools
- Identify subset of systems with Guaranteed Engineering
- Develop Management Policies (e.g., policies for everything: purchasing, replacements of equipment, supply chain, etc.) Policies For ALL

The Industrial Energy Audit Results

	Pesimist	Optimist	Cost	SPP	Type of Opportunities
I	0%	5%	Maint. Budget	0	Routine & Reactive Maintenance Operations
II	5%	15%	No Investment Cost	< 1 yr	Eliminate/reduce leaks: water, steam & air, change operations set-ups of equipment, high eff. motors, boilers condensate return, among others
III	15%	30%	Low Investment Cost	1 to 5 years	Insulation, Power Factor reduction, recover heat from steam bleeding, economizers in boilers, efficiency increase, evaporators, etc.
IV	30%	50%	Major Investment Cost	> 5 yrs	Boilers insulation, evaporators, biogas generation from biomass, cogeneration systems from biomass, or to satisfy thermal loads for heating or cooling, etc.




The WWTPs Case




Energy Use in WWTPs

Group	Plant	Rated Capacity (MGD)	Rated Capacity (MG/yr)	Wastewater Treated (MG/yr)	Total Energy (MMBtu/yr)	Electricity (kWh/yr)	Natural Gas (MMBtu/yr)
I	A	52.5	19,162.5	8,860.8	302,986.9	35,968,031	180,264
	B	43	15,695.0	14,391.0	152,100.4	42,058,447	8,597
	C	33	12,045.0	8,206.3	166,378.1	28,473,059	69,228
II	D	26.5	9,672.5	6,524.7	122,336.9	18,074,400	60,667
	E	15	5,475.0	7,439.7	57,966.2	16,988,917	0
	F	14.5	5,292.5	4,080.8	26,896.3	7,882,844	0
	G	13.7	5,000.5	3,142.0	25,187.8	7,077,600	1,039
III	H	10	3,650.0	3,472.6	42,037.2	12,320,400	0
	I	9	3,285.0	2,415.6	23,367.7	6,848,676	0
	J	7.5	2,737.5	2,659.5	33,748.6	9,891,135	0

Comparison Between Rated Capacity and WW Treated




Annual Energy Use




Energy Baseline


Total Energy Use vs. Plant Rated Capacity



Total Energy Use vs Actual Amount of WW Treated






Total Energy Baseline - Plant C



Electric Energy Use Distribution

Energy Baselines for All Ten Plants				
		m	b	R ²
Group		(MMBtu/MG)	(MMBtu)	(%)
I	A	-1.4834	26,344	2.05
	B	0.4032	12,283	0.51
	C	4.1152	12,100	1.98
II	D	5.8238	7,028.20	6.77
	E	-0.2552	4,988.90	0.06
	F	2.5126	1,386.90	13.98
	G	1.2981	1,780.30	6.77
III	H	-582.54	1.00E+06	5.47
	I	0.6619	1,814.10	0.62
	J	2,759.70	212,644	49.89

		Energy Cost (from slope m)	Non-Treatment Cost (from intercept b)
Group		(\$/MG)	(\$)
I	A	13.71	243,566
	B	6.65	202,394
	C	42.3	124,370
II	D	102.98	124,294
	E	4.67	91,390
	F	46.55	25,679
	G	22.25	38,517
III	H	54.8	94,000
	I	15.52	42,453
	J	173.9	13,397





Energy Savings Opportunities

ARs	GROUP I			GROUP II				GROUP III		
	A	B	C	D	E	F	G	H	I	J
Replace blowers with air compressors	√	√				√				
Turn on the UV controller	√									
Install high-efficiency motors	√	√			√	√	√	√	√	√
Put oxygen sensor in boiler's exhaust	√									
Install a CHP system		√								
Install CHP or CNG syst. using biogas				√						
Install high-efficiency lighting		√	√	√			√			
Insulate tanks			√							
Enhance biogas generation			√							
Install occupancy sensors			√				√			
Replace V-belts with cogged V-belts			√		√	√	√			
Install an energy management System			√	√						√
Preheat the air to the dryer				√						
Install O ₂ sensor in boiler exhaust				√			√			
Install variable frequency drives					√				√	√
Install heat recovery for the boiler							√			
Install a photovoltaic system								√		
Install higher eff. blades in aerators								√		
Turn off the digester's pumps								√		
Install pipes for biomass transport								√		
Install timers for outside lights								√		
Treat rejected water with ozone									√	
Optimize comp. air vol. generation										√
Install a back-up generator switch										√
Energy Cost Savings (\$/yr)	480,698	274,070	331,342	222,530	128,672	256,917	50,986	146,122	95,000	120,627
% of Energy Costs Saved	17.16	8.16	16.22	11.82	12.10	51.73	10.00	10.75	17.34	19.43

Productivity Increase Opportunities

ARs	GROUP I			GROUP II				GROUP III		
	A	B	C	D	E	F	G	H	I	J
Install a reactor for nutrient recovery	√	√		√						
Automate the aeration process								√		
Productivity Cost Savings (\$/yr)	493,101	492,292		495,807				70,421		

Waste Management Opportunities

ARs	GROUP I			GROUP II				GROUP III		
	A	B	C	D	E	F	G	H	I	J
Install a Biodigester										√
Cost Savings (\$/yr)										396,790

Total Cost Savings Opportunities

ARs	GROUP I			GROUP II				GROUP III		
	A	B	C	D	E	F	G	H	I	J
TOTAL COST SAVINGS	973,799	766,362	331,342	718,337	128,672	256,917	50,986	216,543	95,000	517,417

Cost and Energy Savings for the Three Groups of WWTPs

	Cost Savings	Implementation Cost	Simple Payback Period	Return on Investment	Electric Energy Savings	Thermal Energy Savings	CO ₂ Reduction
GROUP	(\$/yr)	(\$)	(yrs)	(%/yr)	(kWh/yr)	(MMBtu/yr)	(tons CO ₂ /yr)
I	2,199,991	6,973,813	3.17	31.55	20,454,658	146,290.0	1838.6
II	6,938,084	639,958	0.09	1,084.15	2,574,181	82,593.5	1369.9
III	829,404	1,953,407	2.36	42.46	3,734,988	145,611.0	3146.0
Total	9,967,479	9,567,178			26,763,827	374,494.5	6,354.5


Total annual cost savings of all plants is about \$9,967,479

This represents a plant average of \$996,748/yr in savings

Total reduction in energy consumption per plant is about 17.5%

A Combined Heat and Power System or CNG

Consider the following diagram and run some energy calculations.



Nat Gas Savings = Fuel Energy - Heat For Boiler

= 85,397 MMBtu/yr - 34,159 MMBtu/yr = 51,238 MMBtu/yr

Cost Savings = Demand + Energy - Fuel - Maintenance

Payback = Imp. Cost/Cost Savings = \$1,400,000 / \$302,404/yr = 4.63 yrs (3.45 yr)

Return on Investment = (\$302,404/yr / \$1,400,000) x 100 = 21.60%/yr (28.92%/yr)

DOE CHP Technical Assistance Partnerships (CHP TAPs)

Upper-West
CO, MT, ND, SD, UT, WY
www.uwchptap.org
Gavin Dillingham, Ph.D.
HARC
281-216-7147
gdillingham@harcresearch.org

Midwest
IL, IN, MI, MN, OH, WI
www.mwchptap.org
Cliff Haeffel
University of Illinois at Chicago
312-355-3476
chaeffel@uic.edu

New England
CT, MA, ME, NH, RI, VT
www.nechptap.org
David Dvorak, Ph.D., P.E.
University of Maine
207-581-2338
dvorak@maine.edu

Northwest
AK, ID, OR, WA
www.nwchptap.org
David Van Holde, P.E.
Washington State University
360-956-2071
VanHoldeD@energy.wsu.edu



New York-New Jersey
NJ, NY
www.nynjchptap.org
Tom Bourgeois
Pace University
914-422-4013
tbourgeois@law.pace.edu

Western
AZ, CA, HI, NV
www.wchptap.org
Carol Denning
Center for Sustainable Energy
530-513-2799
carol.denning@energycenter.org

Mid-Atlantic
DC, DE, MD, PA, VA, WV
www.machptap.org
Jim Freihaut, Ph.D.
The Pennsylvania State University
814-863-0083
jdf11@psu.edu

Southcentral
AR, LA, NM, OK, TX
www.schptap.org
Gavin Dillingham, Ph.D.
HARC
281-216-7147
gdillingham@harcresearch.org

Central
IA, KS, MO, NE
www.cchptap.org
Cliff Haeffel
University of Illinois at Chicago
312-355-3476
chaeffel@uic.edu

Southeast
AL, FL, GA, KY, MS, NC, PR, SC, TN, VA
www.sechptap.org
Isaac Panzarella, P.E.
North Carolina State University
919-515-0354
ipanzarella@ncsu.edu


**DOE CHP Deployment
Program Contacts**
www.energy.gov/CHPTAP

Robert "Bob" Schmitt
Technology Manager
Office of Energy Efficiency and
Renewable Energy
U.S. Department of Energy
Robert.Schmitt@ee.doe.gov


Patti Garland
DOE CHP TAP Coordinator [contractor]
Office of Energy Efficiency and
Renewable Energy
U.S. Department of Energy
Patricia.Garland@ee.doe.gov

Electric Energy Stabilizer

Energy Savings Distribution



Demand Savings Distribution



IC = \$30,000

CS = \$37,000/yr

SPP = 0.81 yrs

Integrate IoT Into SCADA System

IC = \$10,000

CS = \$47,000/yr

SPP = 0.21 yrs

Implement a Remote Access to SCADA-HMI

IC = \$0

CS = \$5,000/yr

SPP = Immediate

Sell Sludge as Fertilizer



IC = \$53,000

CS = \$560,000/yr

SPP = 0.10 yrs

In Summary

- Free Energy Audits
- Free CHP – TAP Evaluation
- MACRS
- New Implementation Funding Resources

CONCLUSIONS

- There are opportunities for on-site power generation using CHP.
- NCRE such as photovoltaics (PV) can be made part of the plants' energy use portfolio.
- The correlation of electric energy usage with the amount of wastewater treated for plants with only electric energy capability is poor. The same is true for the linear correlation of natural gas energy usage with the amount of wastewater treated. Poor linear correlation is also observed between the electric energy usage and the amount of wastewater treated for those plants that use both modes of energy.
- Energy used per MG of WW treated is below recommended values by the US - DOE.
- Equipment runs a fraction of the annual hours of operation, but not necessarily at the same time.
- Electric equipment has different operating parameters, efficiencies and capacities.
- Plants that do not further treat their sludge, have great opportunities to generate biogas and biofertilizers, and self-generate power through CHP. All with very appealing savings.

What is not a best practice becomes a recommendation



Questions ?



GATOR
Engineering



UNIVERSITY OF
FLORIDA